

DRAWN BY:
KJB/LRR

DATE:
02/25/2004

PSU NH Roof Area Totals						
Circulation	Number	Sub-room	Area	LAYER	AREA AT	Quantity
-	601	-	292.5 SF	AREA-ME		1
-	ROOF	-	196.3 SF	AREA-ROOF	ROOF LEFT OF 601	1
-	ROOF	-	2086.1 SF	AREA-ROOF	ROOF AT 601	1
-	ROOF	-	2397.7 SF	AREA-ROOF	ROOF AT SOUTH	1
-	ROOF	-	7111.7 SF	AREA-ROOF	ROOF AT WEST	1
TOTALS			12084.2 SF			5

PSU Gross Area				
Circulation	Number	Sub-room	Area	LAYER
-	GROSS	-	335.2 SF	AREA-GROSS

PSU Mechanical Area					
Circulation	Number	Sub-room	Area	LAYER	Quantity
-	601	-	292.5 SF	AREA-ME	1
TOTALS			292.5 SF		1

PSU Roof Area						
Circulation	Number	Sub-room	Area	LAYER	AREA AT	Quantity
-	ROOF	-	7111.7 SF	AREA-ROOF	ROOF AT WEST	1
-	ROOF	-	196.3 SF	AREA-ROOF	ROOF LEFT OF 601	1
-	ROOF	-	2086.1 SF	AREA-ROOF	ROOF AT 601	1
-	ROOF	-	2397.7 SF	AREA-ROOF	ROOF AT SOUTH	1
TOTALS			11791.7 SF			4

ROOF AREA TABLES
NEUBERGER HALL
724 S.W. HARRISON
AREA CALCULATIONS

FACILITIES
617 SOUTHWEST
MONTGOMERY STREET
PORTLAND, OR. 97201
www.fac.pdx.edu
TEL: 503-725-3738
FAX: 503-725-4329